



Note :-

- 1-The casing material will be PVC.
- 2-The delivery pipe material will be PVC or PP-R Pipe.
- 3-Equivalent imperial distances the well must be :
 - 50 M from sewage effluent discharge the ground surface.
 - 100 M -from a sewage lagoon.
 - 3-4 M from existing buildings.
 - 6 M from the road and public highway.